

Item #	Building	Floor Tiles (& mastic)	Above Ceiling Fire Proofing	Mudded Pipe Fittings	Ceiling Tiles	Pipe Insulation	
1	31. Hinman Dining Hall - Constructed 1968						
2	Ground Floor	No	No	Yes	No	PACM	
3	First Floor	No	No	Yes	No	PACM	
4	Penthouse	No	No	Yes	N/A	Abated	

Mechanical Rooms	Gasket Material	Window Caulking	Transite	Dry Wall Compound	Crawl Space	Fire Doors
Abated	PACM	N/A	No	PACM	N/A	Yes
N/A	PACM	PACM	No	PACM	N/A	No
N/A	PACM	N/A	Yes	N/A	N/A	No