

Item #	Building	Floor Tiles (& mastic)	Above Ceiling Fire Proofing	Mudded Pipe Fittings	Ceiling Tiles	Pipe Insulation
1	34. Lecture Hall - Constructed 1968					
2	Basement	Yes	Yes	PACM	N/A	N/A
3	First Floor	Yes	Abated	PACM	No	PACM
4	Second Floor	Yes	Yes	PACM	No	PACM
5	Third Floor	Yes	Abated	PACM	No	PACM
6	Fourth Floor	Yes	N/A	PACM	No	PACM

Mechanical Rooms	Gasket Material	Window Caulking	Transite	Dry Wall Compound	Crawl Space	Fire Doors
Abated	PACM	PACM	N/A	PACM	N/A	Yes
N/A	PACM	PACM	N/A	PACM	N/A	Yes
N/A	PACM	PACM	N/A	PACM	N/A	Yes
N/A	PACM	PACM	N/A	PACM	N/A	Yes
Office E-wing Abated	PACM	PACM	N/A	PACM	N/A	Yes